



UST Field Notice of Non-compliance

No. 1104

The Environmental Protection Agency (EPA) is responsible for the enforcement of underground storage tank (UST) laws that protect human health and the environment. Pursuant to federal regulation at 40 CFR Part 280, during an inspection on

6-17-04

(Date)

the following items of UST non-compliance were observed at your facility:

1	Description: 280.44(a) Failure to conduct annual test of the automatic Line Leak detectors (ALLD)	Correction Required: Conduct and provide test results of the ALLD's	Deadline: 7-17-04
2	Description: 280.31(c) Failure to inspect impressed current system every 60 days	Correction Required: provide copy of the next two readings.	Deadline: 10-17-04
3	Description:	Correction Required: Next Cathodic Protection Test due by 10-04	Deadline:
4	Description:	Correction Required:	Deadline:

WARNING

The EPA wishes to work cooperatively with you as the owner and/or operator of this facility to resolve the violation(s) listed above at this time. Therefore, no penalty will currently be assessed. However, if you fail to complete the above noted compliance task(s) before the listed deadline(s), you will become subject to citation and/or formal enforcement action. Such enforcement actions mandate compliance and carry monetary penalties as high as \$11,000 for every day of continued violation on each underground tank.

Notify your EPA contact person (listed below) immediately if you are unable to perform the required actions within the specified dates.

EPA Inspector	Facility Information
Name: Jim Greeves	Name of Facility: Smitty's Conoco
Office Address: EPA WA operations Office 300 Desmond Dr SE ST102 Lacey WA 98503	Facility ID #: 4260087
Phone: 360-753-8072 / FAX-8080	Address: 102 E Toppenish Toppenish, WA 98948
Signature: Jim Greeves	Contact: Albert Rodriguez
	Phone: 209 office 882 3377
	Signature: Albert Rodriguez (Signature acknowledges receipt only)